

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
(215) 887-3730



# Invoice

Date	Invoice #
5/16/2024	75280

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	5/15/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH430835 with new twp pump DH886066 Frank Cacciutti 100 Woodhill LN Media PA 19063  Date of service 5/16/24 Technician Pat Brady  Arrived on site and found pump DH430835 not in alarm Took meter readings and brown to black was incorrect pulled pump for further evaluation and found corroded control housing Worn cutter wheel/stator and corroded switches on/off side had a broken tab.Due to age of pump installed new upper Providence core DH886066 pump pumped down and shut off at 6.1 amps pump is running correctly				
1 1.5	Service/Ins Labor-PB	Service Call & Inspection Fee < Labor rate for Pat			170.00 130.00	170.00 195.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Subtotal</b>	\$365.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$365.00
	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$365.00