

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

Date	Invoice #
5/27/2024	75316

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	5/20/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH511628 with new Twp pump DH886055 Steve Moppert (Upper Prov) 130 Springfield Lake Rd Media, Pennsylvania 19063-1826				
		Date of service 5/20/24 Technician Pat Brady				
		Arrived on site and found pump DH511628 in alarm and Thermal out bearings were making loud grinding noises. All meter readings were incorrect. Pulled pump for further evaluation and due to age of pump installed new upper Providence core DH886055 pump pumped down and shut off at 6.1 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
1.5	Labor-PB	Labor rate for Pat			130.00	195.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$365.00
Sales Tax (0.0%)	\$0.00
Total	\$365.00
Payments/Credits	\$0.00
Total Due	\$365.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.