

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

Date	Invoice #
5/28/2024	75385

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JohnS	5/28/2024			
Qty	Item Code	Description			Price Each	Amount
		DH886146 Thomas Leaver 3000 N Providence Rd Media PA 19063				
		Date of service 5/28/24 Technician John Simons				
		Arrived on site due to customer stated in the pump went into Alarm and also had a run dry occurrence. Performed meter checks and all readings were correct. Performed Meg test and found that L2 and Alarm return wires were shorted. Installed a 50 foot supply cable above ground and wired into panel. Test DH886146 and it operates at 5.9 amps. Job complete				
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
2	Labor-JS	Labor rate for John Simons			130.00	260.00
1	ND0036G07	50' Length Supply cable for Extreme Series			56.81052	56.81

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$486.81
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$486.81
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$486.81

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.