

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
7/1/2024	75912

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	7/1/2024			
Qty	Item Code	Description			Price Each	Amount
1 1.5	Service/Ins Labor-SGon	Replace DH387366 with new twp pump DH896932 Larry Fiscus (Upper Prov) 160 Sycamore Mills Rd Media, Pennsylvania 19063-2026  Date of service 7/1/24 Technician Sebastian Gonzalez  Arrived on site to find panel in alarm. Performed meter readings and the only thing that was fine was voltage to pump and panel. Everything else had floating shorts on all readings. I pulled pump #DH387366 out of station and noticed that pump is severely corroded and also the pump is from 09/2010. Went to upper Prov shed and grabbed a new core #DH00896932 and put the new core into station. Ran pump to alarm and performed my last meter readings and everything came out fine.  Job complete.  Service Call & Inspection Fee < Labor rate for Sebastian		170.00 130.00	170.00 195.00	

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$365.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$365.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$365.00