

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
7/5/2024	75985

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	7/5/2024			
Qty	Item Code	Description			Price Each	Amount
1 1.5	Service/Ins Labor-PB	Replace DH465307 with new twp pump DH896935 David Snyder 360 E Rose Tree Rd Media PA 19063 Date of service 7/5/24 Technician Pat Brady Arrived on site and found pump DH465307 in over pressure alarm reset breakers took Meter readings all readings were correct.Pulled pump for further evaluation and found that the motor housing/control housing is corroded beyond repair.Also station had lots of grease cleaned out station best I could installed upper Providence new core DH00896935 pump pumped down and shut off at 6.1 amps pump is running correctly Service Call & Inspection Fee Labor rate for Pat		170.00 130.00	170.00 195.00	

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$365.00
	Sales Tax (0.0%)	\$0.00
	Total	\$365.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$365.00