

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
7/11/2024	76081

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	7/11/2024			
Qty	Item Code	Description			Price Each	Amount
1 1.5	Service/Ins Labor-PB	DH838190 Carolyn Dunn 6 Camby Chase Rd Media PA 19063  Date of service 7/9/24 p Technician Pat Brady  Arrived on site and found pump DH838190 not in alarm Took meter readings all readings were correct cycled pump and pump pumped down and shut off contactor would switch off. Changed out contactor took meter readings again megged cable cycled pump pump pumped down and shut off at 5.8 amps pump is running correctly  Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 195.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$365.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$365.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$365.00