

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
7/12/2024	76131

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	7/12/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace DH432995 with new Twp pump DH896945 Drew Martin (Upper Prov) 201 Timber Jump Ln Media, Pennsylvania 19063-1133				
1	Labor-PB	Date of service 7/12/24 Technician Pat Brady Arrived on site and found pump DH432995 in high level alarm called to run not evacuating the station. Took meter readings and all readings were incorrect and there were shorts On all pump leads went to pull pump for further evaluation found station was flooded and house side cable is tight against the station. Due to age of pump installed new upper Providence core DH00896945 pump pumped down and shut off at 5.7 amps pump is running correctly. Will need to have a new cable installed Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

	Subtotal	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
	Payments/Credits	\$0.00
	Total Due	\$300.00