

## *Site Specific Design, Inc.*

1704 Rockwell Road  
Abington, PA 19001



## Invoice

Date	Invoice #
7/17/2024	76190

215-887-3730

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	7/22/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins Labor-PB	Replace DH429243 with new twp pump DH903383 Maryann Budike 2973 Lakewood Dr Media PA 19063  Date of service 7/17/24 Technician Pat Brady  Arrived on site and found pump DH429243 in high level alarm and not evacuating the station meter readings brown to red and black were incorrect pulled pump for further evaluation found control housing bolt holes corroded through and due to age of pump installed new upper Providence core DH00903383 pump has been installed and cycled pump pumped down and shut off at 6.0 amps pump is running correctly			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00