

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
7/22/2024	76252

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JohnS	7/22/2024			
Qty	Item Code	Description			Price Each	Amount
1	DH433588 Service/Ins 1 Labor-JS	DH433588 William Talp (Upper Prov) 115 W Bishop Hollow Rd Media, Pennsylvania 19063-4341 Date of service 7/22/24 Technician John Simons Arrived on site due to customer stating that when the toilets are flushed the shower backs up. The homeowner said he had a plumber snake the lines and they are clear. Performed meter test and all readings are correct. Manually operated DH433588 and it runs at 5.7 amps. Put a garden hose into the vent pipe and turned water on. The pump turns on and cycled properly. Determined there is a problem with his gravity line. Referred the customer to Hickman sanitation to have line inspected and jetted if possible. Job complete Service Call & Inspection Fee Labor rate for John Simons			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$300.00
	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$300.00