

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
7/24/2024	76297

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	7/24/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace DH433848 with new twp pump DH903387 Mike Henderson (Upper Prov) 471 Berry Ln Media, Pennsylvania 19063-1160				
2.5	Labor-PB	Date of service 7/24/24 Technician Pat Brady				
1	Pump Truck	Arrived on site and found pump DH433848 in over pressure alarm and all meter readings were incorrect pulled pump for further evaluation and found station had balls rages wipes bunch of non flushable material.I spoke with homeowner about the pump and what was in the station.called Hickman sanitation to pump out station .Due to the age and corrosion of top housing and motor housing installed new upper Providence core.DH00903387 Pump pumps down and shut off at 5.9 amps pump is running correctly Service Call & Inspection Fee Labor rate for Pat Pump truck called out to evacuate station.			170.00 130.00 441.80	170.00 325.00 441.80

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$936.80
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$936.80
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$936.80