

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
7/25/2024	76325

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	7/25/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins 1 Labor-SGon	Replace DH402913 with new twp pump DH902806 Christopher Stewert (Upper Prov) 120 Kelly Ln Media, Pennsylvania 19063-2047  Date of service 7/25/24 Technician Sebastian Gonzalez  Arrived on site to find panel in alarm. Performed meter readings and all readings were bad except voltage from pump to panel. Pulled pump DH402913 out from station and saw that it was flooded. I also noticed pump was from 04/2011 I went to upper Prov shed to grab new core #DH00902806. Put new pump into station and ran pump to alarm. Performed my last meter readings and all readings came back fine.  Job completed.  Service Call & Inspection Fee Labor rate for Sebastian		170.00 130.00	170.00 130.00	

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$300.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$300.00