

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
7/26/2024	76337

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project			
	Net 30	SGon	7/26/2024						
Qty	Item Code	Description			Price Each	Amount			
1	Service/Ins	Replace A237989 with new twp pump DH902804 Arina Goyle (Upper Prov) 475 Old State Rd Media, Pennsylvania 19063-1534							
	1 Labor-SGon	Date of service 7/26/24 Technician Sebastian Gonzalez							
	1 7094	Arrived on site to find panel not in alarm. But breakers to pump were turned off. I performed meter readings and all readings were good except stator and switches. I pulled pump #A237989 out from station and saw that pump is from 07/05. I went to upper Prov shed to grab new pump #DH00902804. I also had to change EQD from 2K series to Extreme. I put new core into station and ran pump to alarm and performed last meter checks and everything came back good.							
	1 1224	Job completed. Service Call & Inspection Fee Labor rate for Sebastian EQD INSERT, FEMALE (SIX PIN) PN 1224 ND0058G01 Conversion Kit, 2000 Tank to Extreme Core			170.00 130.00 29.104 0.00	170.00 130.00 29.10 0.00			
					Subtotal	\$329.10			
					Sales Tax (0.0%)	\$0.00			
					Total	\$329.10			
					Payments/Credits	\$0.00			
					Total Due	\$329.10			

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.