

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
7/1/2025	81080

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	7/1/2025			
Qty	Item Code	Description			Price Each	Amount
		Fumiya Batta (Upper Prov) 293 E Rose Tree Rd Media, Pennsylvania 19063-1125				
		Date of service 7/1/25 Technician Sebastian Gonzalez				
		Arrived on site to find panel in alarm. And panel was reading brownout. Pump was running on 120v and doesn't have the 240v to kick on pump. I was informed by realtor that there was an electrician out here yesterday working inside main breaker. Called Mr Matson and informed him about the situation and he said to install new core due to old pump being from 07/2014 old core is DH442996 replaced with new core DH00949071. Wasn't able to test pump to any cycle due to insufficient power.				
		Mr Matson will be back on site tomorrow to make sure everything is working properly again.				
		Per Ant this is a no charge				
1	Service/Ins	Service Call & Inspection Fee			0.00	0.00
1	Labor-SGon	Labor rate for Sebastian			0.00	0.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$0.00
Sales Tax (0.0%)	\$0.00
Total	\$0.00
Payments/Credits	\$0.00
Total Due	\$0.00