

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
7/12/2025	81471


Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	7/12/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH428167 with new twp pump DH00952225  Edward Henry (Upper Prov) 181 Steeplechase Dr Media, Pennsylvania 19063-1954  Date of service 7/12/25 Technician Sebastian Gonzalez  Arrived on site to find panel in alarm. Performed meter readings and all readings to pump were good except switches and I wasn't getting any amps to pump. I lifted up lid to station to find station flooded and I pulled pump DH428167 and saw that pump was from 06/2012 I went to upper Prov shed to grab customer new core DH00952225. I put new core outside of station and megged cables inside panel and readings came back good. Installed new core and was able to run pump in and out of alarm. And was able to run pump to its normal cycle.  Amps on new pump 5.7				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

**OK TO PAY**  
**KEVIN MATSON, PE,**  
**OPERATIONS MANAGER**

  
08/11/25