

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
7/17/2025	81549


Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	7/17/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433533 with new twp pump DH00952214 John Dezell (Upper Prov) 120 Daria Rose Ct Media, Pennsylvania 19063-1188 Date of service 7/17/25 Technician Sebastian Gonzalez Arrived on site to find panel in alarm. Performed meter readings and all readings to pump were good except switches and amps. I went to station to find station flooded. I managed to pull pump DH433533 and saw that pump was from 07/2012 I went to upper Prov shed to grab customer new core DH00952214. Before installing I went to panel to meg cables and all readings were good. Installed new core and was able to run pump in and out of alarm. And run pump to its normal cycle. Amps on pump is 5.6				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

OK TO PAY
KEVIN MATSON, PE,
OPERATIONS MANAGER


08/11/25