

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
7/27/2025	81698

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	NB	7/27/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433693 with new twp pump DH00952182  Lisa Liebman (Upper Prov) 342 Foxdale Road Media, PA 19063  Date of service 7/27/25 Technician Nick Butkewicz  Arrived on site and found the panel in alarm and the pump running. They are both in the front of the house. Pump was running at 5.4 Amps. I performed my meter readings and they looked normal. I opened the station and there was a few inches of water. I pulled pump# DH433693 and brought it to my van for inspection. I saw that the pump was 13 years old so I decided to put a new pump in. I installed pump# DH00952182. Pump cycled through and shutoff. Pump ran at 5.3 Amps. Job complete  Note: I grabbed pump# DH00952182 from Upper Providence's shed.				
1	Emergency 1.5 Labor Nick Butke...	Emergency Weekend/After Hours Rate Emergency Labor Nick Butkewicz			200.00 225.00	200.00 337.50
					<b>Subtotal</b>	\$537.50
					<b>Sales Tax (0.0%)</b>	\$0.00
					<b>Total</b>	\$537.50
					<b>Payments/Credits</b>	\$0.00
					<b>Total Due</b>	\$537.50

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

**OK TO PAY**  
**KEVIN MATSON, PE,**  
**OPERATIONS MANAGER**

08/11/25