

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
8/1/2024	76402

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	8/1/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Elizabeth & John King (Upper Prov) 5 W Bishop Hollow Rd Media, Pennsylvania 19063-4343				
1	Labor-PB	Date of service 7/31/24 Technician Pat Brady  Arrived on site and found that there was improper voltage to the panel. Electrician was out yesterday and since then they been having back ups in the basement. Meter readings show that there is only one leg of power. I explained to homeowner that when they get the power right turn breakers back on and how to silence the alarm and it will take a minute to pump out of alarm  Service Call & Inspection Fee Labor rate for Pat			170.00	170.00
					130.00	130.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

**OK TO PAY**  
**KEVIN MATSON, PE,**  
**OPERATIONS MANAGER**

09/09/2024

