

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
8/6/2024	76480

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	8/6/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH387291 with new twp pump DH896324 Mike Giambra (Upper Prov) 30 Sycamore Ct Media, Pennsylvania 19063-2048				
		Date of service 8/6/24 Technician Sebastian Gonzalez				
		Arrived on site to find panel in alarm. Performed meter readings and all readings came out good. But amps and switches. I pulled the lid off of station and noticed that station was flooded. I pulled pump number #DH387291 out of station And I also noticed that pump was from 09/2010 I went to upper Prov shed and grabbed new core number. DH00896324. I put new pump into station and ran pump to alarm and performed my last meter readings and everything came back good.				
		Job complete				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00
1	Pump Truck	Pump truck called out to evacuate station.			441.80	441.80

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Subtotal</b>	\$741.80
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$741.80
	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$741.80