

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
8/7/2024	76500

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	8/7/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace A138933 with new Twp pump DH886056 Kayla Testa (Upper Prov) 8 Azalea Ln Media, Pennsylvania 19063-2240 Date of service 8/7/24 Technician Pat Brady Arrived on site and found pump in alarm but customer didn't know where the Pump was located in the forest cut down all the bushes located the pump A138933 pulled pump for further evaluation found check valve broken and motor was flooded. Due to age of pump installed new upper Providence core DH886056 pump pumped down and shut off at 6.1 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee		170.00	170.00	
3.5	Labor-PB	Labor rate for Pat		130.00	455.00	
1	1224	PN 1224 ND0058G01 Conversion Kit, 2000 Tank to Extreme Core		75.6925	75.69	

All material remains the property of Site Specific Design until final payment.

Subtotal	\$700.69
Sales Tax (0.0%)	\$0.00
Total	\$700.69
Payments/Credits	\$0.00
Total Due	\$700.69

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.