

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
8/10/2024	76562

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	8/10/2024			
Qty	Item Code	Description			Price Each	Amount
		Repair DH896336 Steve Phipps (Upper Prov) 691 West 3rd Street Media, PA 19063				
		Date of service 8/10/24 Technician Sebastian Gonzalez				
		Arrived on site to find panel on alarm. Performed meter readings and all readings were good except amps were running on 4.0/4.2. I pulled pump #DH00896336 and noticed that pump was from 05/2024. I checked pump switches and they were good. I replaced the stator and put pump back into station and ran pump to alarm. I performed my final meter readings and everything was good.				
		Job completed				
		Stator coverd under Site Warranty.				
1	Emergency	Emergency Weekend/After Hours Rate			200.00	200.00
2	Labor-SGon	Emergency Labor rate for Sebastian			225.00	450.00
1	8203	STATOR/LINER ASSY EXTREME NC0039G01			0.00	0.00

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$650.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$650.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$650.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.