

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
8/16/2024	76687

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	8/16/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH402853 with new twp DH905847 Robert Church (Upper Prov) 1268 Hunt Club Lane Media, PA 19063 Date of service 8/16/24 Technician Pat Brady Arrived on site and found pump DH402853 not in alarm had homeowner run water pump went into alarm pump out of alarm and making grinding noise.due to age of the pump installed new upper Providence core DH00905847 pump pumped down and shut off at 6.1 amps pump is running correctly				
1	Service/Ins 1 Labor-PB	Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 130.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

