

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
8/20/2024	76734

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	8/20/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH434099 with new Twp pump DH899865 Marc Wink (Upper Prov) 2218 E Deerfield Dr Media, Pennsylvania 19063-1834				
		Date of service 8/20/24 Technician Pat Brady				
		Arrived on site and found pump DH434099 in high level alarm and not running all meter readings were incorrect also shorts to every pump lead Went to pull pump from station For further evaluation and had to cut weeds away and dig station out some.Pumps rotor was locked up and control housing was heavily Corroded.Due to age of pump installed new upper Providence core DH899865 pump pumped down and shut off at 6.4 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-PB	Labor rate for Pat			130.00	130.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$300.00
	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$300.00

