

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
8/21/2024	76161

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	7/13/2024			
Qty	Item Code	Description			Price Each	Amount
		On call Replace DH385737 with new twp pump DH906267 Steve Phipps (Upper Prov) 691 W 3rd St Media, Pennsylvania 19063-2201 Date of service 7/12/24 & 8/21/24 Technician Jon McKee & Pat Brady				
		Arrived on site, customer's pump was going into alarm several times for approximately 10 minutes before clearing itself. Inspected panel, panel OK. Pulled pump DH385737 and installed SSD Spare, S.N. DH468317 and tested spare. Pump turns on and off as required and evacuated within factory specifications. Bringing pump DH385737 back to Rockwell for evaluation.				
		8/21/24 pat Arrived on site to pull site spare and install upper Providence new core DH00906267 pump pumped down and off at 6.0 amps pump is running correctly				
1	Emergency	Emergency Weekend/After Hours Rate			200.00	200.00
1	Labor-Jon M	Emergency Labor-Jon M			225.00	225.00
1.5	Labor-PB	Field Labor rate for Pat			130.00	195.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$620.00
Sales Tax (0.0%)	\$0.00
Total	\$620.00
Payments/Credits	\$0.00
Total Due	\$620.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.