

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

| Date | Invoice # |
|----------|-----------|
| 8/6/2024 | 76476 |

| Bill To | Ship To |
|---|---|
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 | Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | | Project |
|------------|-----------------------------|--|-----------|----------|------------------|------------------|
| | Net 30 | SGon | 8/6/2024 | | | |
| Qty | Item Code | Description | | | Price Each | Amount |
| | | Replace DH385727 with new twp pump DH903384 Stephen Gibson (Upper Prov) 472 Jacques Ln Media, Pennsylvania 19063-1914 Date of service 8/6/24 Technician Sebastian Gonzalez Arrived on site to find panel not in alarm. I performed meter readings and all readings were good except switches and amps on pump. Panel was also reading over pressure. I pulled pump #DH385727 out from station and saw that station was flooded. I also noticed pump was from 09/2010. I went to upper Prov shed to grab customer new core #DH00903384. I put new core into station and ran pump to alarm. Performed my last meter checks and everything was good. Job complete Service Call & Inspection Fee Labor rate for Sebastian | | | | |
| 1 | Service/Ins 1 Labor-SGon | | | | 170.00 130.00 | 170.00 130.00 |

All material remains the property of Site Specific Design until final payment.

| | |
|---|-----------------------------------|
| Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending. | Subtotal \$300.00 |
| | Sales Tax (0.0%) \$0.00 |
| | Total \$300.00 |
| | Payments/Credits \$0.00 |
| | Total Due \$300.00 |

