

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
8/7/2024	76479

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	8/7/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH431824 with new twp pump DH903390 Glenn & Deborah Ziegler (Upper Prov) 40 Gordon Dr Media, Pennsylvania 19063-1940 Date of service 8/6/24 Technician Pat Brady Arrived on site and found station completely flooded.went to take meter readings but no power to the panel.I called phone number to get intouch with homeowner to to breakers back on in the house but no answer.pulled pump and do to age install new upper Providence core DH00903390 will have to return tomorrow morning to cycle the pump also station needs a 6" riser. 8/7/24 pat Arrived back on site to cycle pump and there still was no power it seems that they are hooked up on a some kind of power module There is no power coming out to the panel I let her know she might have a bad breaker.She called to have an electrician come out .She said that she will call us back when power is back on.				

All material remains the property of Site Specific Design until final payment.

Subtotal

Sales Tax (0.0%)

Total

Payments/Credits

Total Due

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
8/7/2024	76479

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	8/7/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	8/7/24 pat Return to site power was restored pump pumped down and shut off at 6.1 amps pump is running correctly			170.00	170.00
2	Labor-PB	Service Call & Inspection Fee Labor rate for Pat			130.00	260.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$430.00
Sales Tax (0.0%)	\$0.00
Total	\$430.00
Payments/Credits	\$0.00
Total Due	\$430.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.