

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
8/14/2024	76621

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	8/14/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH402893 with new twp pump DH904195 Joanne Arizin (Upper Prov) 6 Pennsford Ln Media, Pennsylvania 19063				
		Date of service 8/14/24 Technician Sebastian Gonzolez				
		Arrived on site to find panel not in alarm but the alarm breaker to panel was turned off. I performed meter readings and all readings were bad except voltage from pump to panel. Went to station and opened up lid and saw that station was not flooded but had chunks of grease on top of station . I pulled pump #DH402893 out of station and saw that pump was from 05/2011. I went to upper Prov shed and grabbed customer new core #DH00904195 . I put new pump into station and ran pump to alarm and performed my last meter readings and everything came back good.				
		Job completed.				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Subtotal</b>	\$300.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$300.00
	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$300.00

**OK TO PAY**  
**KEVIN MATSON, PE,**  
**OPERATIONS MANAGER**

  
09/09/2024