

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
7/25/2024	76214

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	7/25/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433196 with new twp pump DH903385 Philip Pang (Upper Prov) 100 Andrew Cir Media, Pennsylvania 19063-1982				
		Date of service 7/18/24 Technician Sebastian Gonzalez				
		Arrived on site to find panel not in alarm but the alarm breaker was turned off. I performed meter readings and all readings came back bad. I checked the year the of the pump and the pump year was 7/2012. Tristan and I went to the upper Prov shed and grabbed customer a new pump. We pulled pump #DH433196 out of station and saw that it was flooded. We put new pump # DH00903385 into station ran pump to alarm and performed our last meter readings and everything was running fine.				
		Job completed				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$300.00
	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$300.00

OK TO PAY
KEVIN MATSON, PE,
OPERATIONS MANAGER

10/7/2024

