

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
9/3/2024	76818

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	Jon M	9/3/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH386045 with new twp pump DH908750 Diana Dussling (Upper Prov) 1244 Hunt Club Lane Media, PA 19063 Date of service 8/25/24 Technician Jon McKee Arrived on site, station was in active alarm. Pump was short cycling with bearing noise and then activating alarm. Panel condition OK. Inspected basin, basin is a 071-74 and had a massive ant hill inside. Removed most of the debris and removed pump DH386045. Pump had heavy corrosion. Retrieved a new core from the UPPER PROV shed and installed new core DH908750 and tested. Alarm works OK, pump evacuated as required at 5.9 amps. Station is in proper working order.				
1	Emergency 1 Labor-Jon M	Emergency Weekend/After Hours Rate Emergency Labor-Jon M			200.00 225.00	200.00 225.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$425.00
Sales Tax (0.0%)	\$0.00
Total	\$425.00
Payments/Credits	\$0.00
Total Due	\$425.00