

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
9/3/2024	76819

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	Jon M	9/3/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace A127977 with new twp pump DH908755  Christopher Palermo (Upper Prov) 1104 Wooded Way Drive Media, PA 19063  Date of service 8/25/24 Technician Jon McKee  Arrived on site, station is a deep simplex station. Checked panel, panel OK. Voltage OK. Readings to pump were bad. Inspected basin, basin was flooded. Found old 2000 series pump hitting thermal. Removed pump A127977 and retrieved new core from the UPPER PROV Shed. Installed new DH Core, DH908755 and tested. Alarm works OK, pump turns on and off as required and evacuates the station at 5.7 amps. Station is in proper working order.				
1	Emergency	Emergency Weekend/After Hours Rate			200.00	200.00
1	Labor-Jon M	Emergency Labor-Jon M			225.00	225.00
1	1224	PN 1224 ND0058G01 Conversion Kit, 2000 Tank to Extreme Core			75.6925	75.69

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$500.69
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$500.69
	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$500.69

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.