

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
9/3/2024	76848

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	9/3/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH429421 with new twp pump DH908760 Catherine & Richard Hazelton (Upper Prov) 341 Paxon Hollow Rd Media, Pennsylvania 19063-1117 Date of service DH429421 Technician Sebastian Gonzalez Arrived on site to find panel not in alarm but both breakers to panel were turned off performed meter readings and all readings were good except switches on pump and contact coil on pump. I lifted lid to station to find station not flooded. I pulled pump #DH429421 out from station and saw that pump was from 06/2012. I went to upper Prov shed to grab customer new core #DH00908760 I put new core into station and ran pump to alarm and performed my last meter readings and everything came back good. Job completed				
1	Service/Ins 1 Labor-SGon	Service Call & Inspection Fee Labor rate for Sebastian			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal \$300.00
	Sales Tax (0.0%) \$0.00
	Total \$300.00
	Payments/Credits \$0.00
	Total Due \$300.00