

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
9/1/2024	76887

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JohnS	9/1/2024			
Qty	Item Code	Description			Price Each	Amount
		Tim & Jill Sprik (Upper Prov) 401 Berry Ln Media, Pennsylvania 19063-1160				
		Date of service 8/29/24 Technician John Simons				
		Arrived on site to find the alarm breaker off in panel. Performed meter test and all readings were correct indicating that both switches were closed. Turned on the breakers and the pump turned on and operated at 5.3 amps. The alarm sounded. After a minute the alarm cleared and the pump finished its cycle and shut off. Unlatched DH851902 and drained the dry access and the pump turned back on and evacuated the station. The system is operating properly. The customer needs to silence the panel and leave the breakers on. Job complete				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-JS	Labor rate for John Simons			130.00	130.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$300.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$300.00

OK TO PAY  
**KEVIN MATSON, PE,  
OPERATIONS MANAGER**

  
10/7/2024