

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
9/3/2024	76904

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JohnS	9/3/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433140 with new twp pump DH908770 Nick Zagacki (Upper Prov) 190 Timber Jump Ln Media, Pennsylvania 19063-1132 Date of service 8/30/24 Technician John Simons Arrived on site to find the breakers off in the alarm panel. Performed meter test and found dead ground shorts on every pump wire. Removed the lid to station and performed meter checks at the pump and every pin had dead ground shorts. Due to the age of the pump and 2012 and the cost of repairs, retrieved a New Township core DH00908770 from the shed. Removed DH433140 and installed new core. Turned on the breakers and the alarm sounded. Turned on the pump breakers and the pump operates at 5.7 amps. Once the alarm cleared, the pump finished its cycle and shut off. Job complete				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-JS	Labor rate for John Simons			130.00	130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

OK TO PAY
KEVIN MATSON, PE,
OPERATIONS MANAGER

10/7/2024

