

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
9/3/2024	76928

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	9/3/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH437469 with new twp pump DH908749 Rachel Lucente (Upper Prov) 315 Marcella Ln Media, Pennsylvania 19063-2252 Date of service 9/3/24 Technician Sebastian Gonzalez Arrived on site to find panel in alarm. Performed meter readings and all readings were good except amps pump was running on 4.0/4.2. I opened lid to station and saw that station was flooded. I pulled pump DH437469 out from station and saw that pump was from 5/2012 I went to upper Prov shed to grab customer new pump #DH00908749 once I put new pump into station I ran pump to alarm and performed my last meter readings and everything came back fine. Job completed Service Call & Inspection Fee Labor rate for Sebastian				
1	Service/Ins 1 Labor-SGon				170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.