

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
9/3/2024	76931

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JohnS	9/3/2024			
Qty	Item Code	Description			Price Each	Amount
	DH862592	Tim Hulton (Upper Prov) 331 Paxon Hollow Road Media, PA 19063				
		Date of service 9/3/24 Technician John Simons				
		Arrived on site to find that the station was overflowing because the customer turned off the alarm breaker. Once on site found that the alarm has reset and the pump was operating properly. The customer was experiencing alarms during the power issue last week which is why they turned off the breaker. Performed meter checks and all readings were correct removed the lid to station and drained dry access. Also cleaned dry access out with hose. Pump DH862592 cycled several times during this process. The pump operates at 5.6 amps job complete.				
1	Service/Ins 1 Labor-JS	Service Call & Inspection Fee Labor rate for John Simons			170.00 130.00	170.00 130.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00