

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
9/4/2024	76957

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	9/4/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace DH433648 with new twp pump DH908558				
1	Labor-SGon	Dominick Peda (Upper Prov) 40 N Feathering Ln Media, Pennsylvania 19063-1908  Date of service 9/4/24 Technician Sebastian Gonzalez  Arrived on site to find panel in alarm. Performed meter readings and all readings were good. Except switches and amps to pump. Pump was running on 4.2 4.4 amps. I lifted lid to station and saw that station was flooded. I pulled pump #DH433648 out from station and saw that pump was from 03/2012. I went to upper Prov shed to grab customer new pump #DH00908558 once I put new pump into station I ran pump to alarm and performed my last meter readings and everything came back fine. Job completed.  Service Call & Inspection Fee Labor rate for Sebastian			170.00	170.00
1					130.00	130.00

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.