

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

| Date | Invoice # |
|----------|-----------|
| 9/8/2024 | 77029 |

| Bill To | Ship To |
|---------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------|
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 | Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | | Project |
|------------|---------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|------------------|------------------|---------|
| | Net 30 | SGon | 9/8/2024 | | | |
| Qty | Item Code | Description | | | Price Each | Amount |
| 1 | Emergency 1 Labor-SGon | Replace DH512113 with new twp pump DH906098 Kevin Bird (Upper Prov) 1770 N Ridley Creek Rd Media, Pennsylvania 19063-4528 Date of service 9/8/24 Technician Sebastian Gonzalez Arrived on site to find panel in alarm. Performed meter readings and all readings came back good except switches and amps on pump. I opened up lid to station to see station not flooded. I pulled pump #DH512113 and I noticed pump was from 08/2011. I went to the upper Prov shed to grab customer new pump #DH00906098. Once I put new pump into station I ran pump to alarm and performed my last meter readings and everything was good. Job completed. | Emergency Weekend/After Hours Rate Labor rate for Sebastian | 200.00 225.00 | 200.00 225.00 | |

All material remains the property of Site Specific Design until final payment.

| | |
|-------------------------------------------------------------------------------------------------------------------------------|-----------------------------------|
| Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending. | Subtotal \$425.00 |
| | Sales Tax (0.0%) \$0.00 |
| | Total \$425.00 |
| | Payments/Credits \$0.00 |
| | Total Due \$425.00 |