

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



215-887-3730

## Invoice

Date	Invoice #
9/9/2024	77037

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	9/9/2024			

Qty	Item Code	Description	Price Each	Amount
		DH486420		
		John Hallinan 107 Water Mill Ln Media PA 19063		
		Date of service 9/9/24 Technician Pat Brady		
		Arrived on site and found pump DH486420 not in alarm and the alarm light was blinking. Open panel and seen breakers were tripped. Took meter readings all readings were correct reset the breakers cycled pump three times pump pumped down and off at 6.6 amps pump is running correctly.		
1	Service/Ins	Service Call & Inspection Fee	170.00	170.00
1	Labor-PB	Labor rate for Pat	130.00	130.00



All material remains the property of Site Specific Design until final payment.

**Subtotal** \$300.00

**Sales Tax (0.0%)** \$0.00

**Total** \$300.00

**Payments/Credits** \$0.00

**Total Due** \$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.