

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
9/10/2024	77054

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	9/10/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace DH433475 with new twp pump DH905897				
1	Labor-PB	Michael Bove 210 W Rose Tree Rd Media PA 19063  Date of service 9/10/24 Technician Pat Brady  Arrived on site and found pump DH433475 in alarm and not pumping out all meter were incorrect pulled pump for evaluation and found pump was corroded and due to age of pump installed upper Providence new core DH00905897 pump pumped down and shut off at 5.8 amps pump is running correctly  Service Call & Inspection Fee Labor rate for Pat			170.00	170.00
					130.00	130.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

