

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



215-887-3730

## Invoice

Date	Invoice #
9/17/2024	77201

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	9/17/2024			

Qty	Item Code	Description	Price Each	Amount
		Replace DH433644 with new twp pump DH911700  Patrick Gallagher (Upper Prov) 500 Foxchase Ln Media, Pennsylvania 19063-1937  Date of service 9/17/24 Technician Pat Brady  Arrived on site and found pump DH433644 in alarm and not evacuating the station took meter readings and brown to red and black were incorrect pulled pump for further evaluation and found corroded control/motor housing and due to the age of the pump Installed new upper Providence core DH00911700 pump pumped down and shut off at 6.1 amps pump is running correctly		
1	Emergency	Emergency Weekend/After Hours Rate	200.00	200.00
1	Labor-PB	Emergency Labor rate for Pat	225.00	225.00



All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$425.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$425.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$425.00