

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
9/24/2024	77286

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	9/24/2024			
Qty	Item Code	Description			Price Each	Amount
1	OK TO PAY KEVIN MATSON, PE, OPERATIONS MANAGER  10/7/2024	Replace DH392817 with new twp pump DH911706 Stu Race (Upper Prov) 280 Sycamore Mills Rd Media, Pennsylvania 19063-2028 Date of service 9/23/24 Technician Pat Brady Arrived on site and found pump DH392817 was In high level alarm and over pressure. Took meter readings all were incorrect. Went to pull pump for further evaluation and found that the station was half buried and thorn bushes covered it . I let homeowner that he will need to cut his bushes away he said to do what I need to do pulled pump the control housing was heavily corroded and due to age of the pump installed new upper Providence core DH00911706 pump pumped down and shut off Pump is running correctly				
0.5	Service/Ins Labor-PB	Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 65.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$235.00
Sales Tax (0.0%)	\$0.00
Total	\$235.00
Payments/Credits	\$0.00
Total Due	\$235.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.