

**UPTSA 2024 Pump Station Invoices**

**Upper Prov./Operations & Maintenance**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
10/4/2025	Upper Providence Township Sewer Authority	2673442	1930867	1	IS-C-WWTP-Lift & Pump Station Operations	\$7,240.33	Monthly O&M	\$7,240.33	6588192175
							<b>Pump Station Total</b>	<b>\$7,240.33</b>	
<b>Upper Prov./Bortondale</b>									

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
10/13/2025	Upper Providence/Bortondal	2673442	1930598	1	Project-C-Hours-Foreman-Mechanic	\$105.21	Responded to a back up float alarm. Reset alarm. Observed proper operations before departure.	\$105.21	6588204909
10/15/2025	Upper Providence/Bortondal	2673442	1930598	4	Project-C-Hours-Mechanic Foreman-OT	\$157.82	Responded to a back up float alarm. and a low level alarm. Reset alarms and tested pumps. Observed proper operation before departure.	\$631.28	6588205138
10/7/2025	Upper Providence/Bortondale	2673442	1930598	4	Project-C-Hours-Foreman-Mechanic-OT	\$157.52	Responded to a back up floats active alarm. Mat in wet well causing obstruction. Wet well needs to be cleaned.	\$631.28	6588204575
10/7/2025	Upper Providence/Bortondale	2673442	1930598	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Cleaned wet well and installed roll pin in air release valve #2.	\$315.63	6588204576
10/7/2025	Upper Providence/Bortondale	2673442	1930598	3	Project-C-Hours-Mechanic	\$97.54	Cleaned wet well	\$292.69	6588204577
10/7/2025	Upper Providence/Bortondale	2673442	1930598	3	Project-C-Hours-Mechanic	\$97.54	Cleaned wet well	\$292.69	6588204578
10/7/2025	Upper Providence/Bortondale	2673442	1930598	4	Project-C-Hours-Pump Truck	\$194.45	Cleaned wet well	\$777.80	6560007493
10/7/2025	Upper Providence/Bortondale	2673442	1930598	1500	Project-C-Disposal-Liquid (Gal)	\$0.08	Disposed of 1500 gallons to Delcora.	\$120.00	6560007493
10/26/2025	Upper Providence/Bortondale	2673442	1930598	4	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a back up float and low level alarms. Reset floats and cleared alarms. Observed proper operation before departure.	\$631.28	6588205785
							<b>Pump Station Total</b>	<b>\$3,797.86</b>	

**Upper Prov./Media Station**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
10/7/2025	Upper Providence/Media Station	2673442	1930601	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Cleaned wet well	\$315.63	6588204579
10/7/2025	Upper Providence/Media Station	2673442	1930601	3	Project-C-Hours-Mechanic	\$97.54	Cleaned wet well	\$292.62	6588204580
10/7/2025	Upper Providence/Media Station	2673442	1930601	2	Project-C-Hours-Mechanic	\$97.54	Cleaned wet well	\$292.62	6588204581
10/7/2025	Upper Providence/Media Station	2673442	1930601	2	Project-C-Hours-Mechanic	\$97.54	Cleaned wet well	\$292.69	6588204582
10/7/2025	Upper Providence/Media Station	2673442	1930601	4	Project-C-Hours-Pump Truck	\$194.45	Cleaned wet well	\$777.80	6560007494
10/7/2025	Upper Providence/Media Station	2673442	1930601	600	Project-C-Disposal-Liquid (Gal)	\$0.08	Disposed of 600 gallons to Delcora.	\$48.00	6560007494
							<b>Pump Station Total</b>	<b>\$2,019.36</b>	

**Upper Prov/Rosetree Estates Upper**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
10/2/2025	Upper Providence/Rose Tree Estates Upper	2673442	1930605	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Cleaned wet well.	\$315.63	6588204207
10/2/2025	Upper Providence/Rose Tree Estates Upper	2673442	1930605	3	Project-C-Hours-Mechanic	\$97.54	Cleaned wet well.	\$292.62	6588204208
10/2/2025	Upper Providence/Rose Tree Estates Upper	2673442	1930605	3	Project-C-Hours-Mechanic	\$97.54	Cleaned wet well.	\$292.62	6588204209
10/2/2025	Upper Providence/Rose Tree Estates Upper	2673442	1930605	3	Project-C-Hours-Mechanic	\$97.54	Cleaned wet well.	\$292.62	6588204210
10/2/2025	Upper Providence/Rose Tree Estates Upper	2673442	1930605	4	Project-C-Hours-Pump Truck	\$194.45	Cleaned wet well.	\$777.80	6560007477
10/2/2025	Upper Providence/Rose Tree Estates Upper	2673442	1930605	1200	Project-C-Disposal-Liquid (Gal)	\$0.08	Disposed of 1200 gallons to Delcora	\$96.00	6560007477
							<b>Pump Station Total</b>	<b>\$2,067.29</b>	

**Upper Prov/Rosetree Estates Lower**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
10/15/2025	Upper Providence/Rose Tree Estates Lower	2673442	1930603	1	Project-C-Hours-Mechanic Foreman	\$105.21	Re-primed bioxide pump	\$105.21	6588205139

10/15/2025	Upper Providence/Rose Tree Estates Lower	2673442	1930603	1	Project-C-Hours-Mechanic Foreman	\$97.54	Re-primed bioxide pump	\$97.55	6588205140
10/20/2025	Upper Providence/Rose Tree Estates Lower	2673442	1930603	2	Project-C-Hours-Mechanic Foreman	\$105.21	Installed new check valve in bioxide pump and primed system.	\$210.42	6588205445
10/20/2025	Upper Providence/Rose Tree Estates Lower	2673442	1930603	2	Project-C-Hours-Mechanic	\$97.54	Installed new check valve in bioxide pump and primed system.	\$195.08	6588205446
10/27/2025	Upper Providence/Rose Tree Estates Lower	2673442	1930603	2	Project-C-Hours-Foreman-Mechanic	\$105.21	Investigated why pump hours were off. Found that the auxiliary for pump #1 had detached. Reattached auxiliary on pump #1.	\$210.42	6588205872
							<b>Pump Station Total</b>	<b>\$818.68</b>	

#### Upper Prov/Valley View

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
10/1/2025	Upper Providence/Valley View	2673442	1930609	1	Project-C-Hours-Foreman-Mechanic	\$105.21	Pump #2 check valve was grounded. Cleaned priming system. Pump #2 back in proper operation.	\$105.21	6588204139
							<b>Pump Station Total</b>	<b>\$105.21</b>	