

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
10/8/2025	82254

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	10/8/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH511425 with new twp pump DH00955901  Greg Marcin 2342 W Deerfield Dr Media PA 19063  Date of service 10/8/25 Technician Sebastian Gonzalez  Pump in alarm. Red light. Arrived on site to find panel in alarm. And panel board was reading run dry performed meter readings and all readings were good but amps. Switches were reading opened. I pulled pump and saw that pump was from 04/2013 and I went to upper Prov shed to grab customer new core DH00955901 before installing pump I went to panel to meg cables and all readings were good installed pump and was able to run pump into both cycles and everything checked out good.				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

