

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



215-887-3730

## Invoice

Date	Invoice #
10/2/2025	82714

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	10/2/2025			

Qty	Item Code	Description	Price Each	Amount
		Replace DH387374 with new twp pump DH00963078  Scott Parson (Upper Prov) 1252 Hunt Club Ln Media, Pennsylvania 19063-2003  Date of service 10/1/25 Technician Sebastian Gonzalez  Alarm. Arrived on site to find panel in alarm. Performed meter readings and all readings to pump were bad. Panel was also reading run dry. Switches on pump was reading closed but I wasn't getting any amps when I pushed/Held run button in panel. I lifted lid to station to find station flooded. I pulled pump DH387374 and saw that pump was from 09/2010 I went to upper Prov shed to grab customer new core DH00963078 before installing new core I went to panel to meg cables and all readings came back good. I. Installed pump and was able to run pump into both cycles. Amps on pump is 5.8		
1	Service/Ins	Service Call & Inspection Fee	170.00	170.00
1	Labor-SGon	Labor rate for Sebastian	130.00	130.00



Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00