

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



215-887-3730

Invoice

Date	Invoice #
10/12/2025	82909

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Project
	Net 30	PB	10/12/2025		

Qty	Item Code	Description	Price Each	Amount
		Replace DH431961 with new Twp pump DH00963068 Steve Teofilak (Upper Prov) 280 West Rose Tree Road Media, PA 19063 Date of service 10/12/25 Technician Pat Brady Arrived on site and found DH431961 had no power asked to see the panel inside the house and seen the breakers were turned off I turned back on the breakers pump went into alarm and wouldn't pump out took meter readings and all readings were incorrect pulled pump for further evaluation pump control cover was heavily corroded and due to age of the pump I installed new upper Providence core DH00963068 cycle the pump pump pumped down and shut off at 5.8 amps pump is running correctly		
1	Emergency	Emergency Weekend/After Hours Rate	200.00	200.00
1	Labor-PB	Emergency Labor rate for Pat	225.00	225.00

OK TO PAY

UPTSA 11/10/2025

Kevin Matson

Subtotal	\$425.00
Sales Tax (0.0%)	\$0.00
Total	\$425.00
Payments/Credits	\$0.00
Total Due	\$425.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.