

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
10/12/2025	82910

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	AD	10/12/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH453196 with new pump DH00963072 Date of service 10/12/25 Technician Pat Brady Pump overflowing. Arrived on site and found pump DH453196 in alarm and brown to red and black were incorrect pulled pump for further evaluation Due to age of pump and corrosion installed new core DH00963072 pump pumped down and shut off at 5.8 amps pump is running correctly				
1	D200A01A01AA	Core, 240V, wired pressure switch, level sensing, 7' core cable, candy cane discharge			0.00	0.00
1	Installation of Ne...	Installation of new Extreme Core w/2 yr warranty. Inspect installation, basin, valve and alarm panel. Inspect EQD & wiring. Remove old pump, identify cause of failure, if possible. Provide warranty documentation. Clean grease and debris accumulation in basin. Install new pump core and test, record performance. Dispose of old components and clean work area.			3,205.00	3,205.00
1	Emergency	Emergency Weekend/After Hours Rate			200.00	200.00
1	Labor-PB	Emergency Labor rate for Pat			225.00	225.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$3,630.00
Sales Tax (0.0%)	\$0.00
Total	\$3,630.00
Payments/Credits	\$0.00
Total Due	\$3,630.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.