

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
10/14/2025	82942

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	KR	10/14/2025			
Qty	Item Code	Description			Price Each	Amount
	<div style="border: 2px solid red; padding: 5px; text-align: center;"> <p>OK TO PAY UPTSA 11/10/2025</p>  <p>Kevin Matson</p> </div>	<p>Tony Sabatelli (upper prov) 630 S Ridley Creek Rd Media, Pennsylvania 19063-4221</p> <p>Date of service 10/14/25 Technician Kevin Rogan</p> <p>Alarm & blinking red light . Arrived on site found panel not in alarm. Initial meter readings were good, no shorts or ground faults on any conductors, readings between switches and alarm circuit all as expected. Had customer run water to cycle system first test pump kicked on via on/off and ran at 6.1 A 246 V , next, simulated high-level alarm;and station pumped itself out of alarm within 2 1/2 minutes and shut down after another 30 seconds of normal operation.</p> <p>All is functioning properly and normally at 246 V at 6.2 A</p> <p>Service Call & Inspection Fee Labor rate for Kevin</p>				
1	Service/Ins 1 labor-KR				170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.