



Water & Wastewater Infrastructure Services

Fax: 610-444-8132

439 McFarlan Road
Kennett Square, PA 19348
Phone: 610-444-3551

November 2024

Attention: Ms. Kelly Verna
935 N. Providence Road
Media, PA. 19063

RE: Sanitary Sewer Operations Maintenance Supervisors Report- November- 2024

1. Operational Status of the facilities & General Pump Station Status

KBX performed the following general pump station repairs and observations:

November- 2024-general pump station repairs:

General Collections:

- 10/31/24-Quarterly Cleaning at Farnum and Crum Creek

Bortondale:

- 11/1/24-Acquired and applied 2001 locks at pump station
- 11/4/24-Switched operations to the new station and tested.
- 11/11/24-Responded to a power failure alarm. Power restored upon arrival. Observed proper operation before departure.
- 11/14/24-Met with contractors to address adjustments to pump station.
- 11/16/24-Responded to a second pump failure alarm. VDF was at fault again. Put pump #2 in lead. Observed proper operation before departure.
- 11/18/24-Put pumps on alternate during the day to evaluate. Observed four cycles.
- 11/18/24-Responded to a pump #1 failure alarm. Put pump #2 in lead. Observed proper operation before departure.
- 11/19/24-Met with contractor to evaluate pump #1 failures. Determined soft start needs to be replaced.
- 11/20/24-Responded to a power failure alarm. Power not restored. Called in power failure to PECO.
- 11/21/24-Met with contractor to have the old pump station de-energized.
- 11/25/24-Removed pumps and components from site during demolition of old station.

- 11/27/24-Pumped down wet well in order for contractor to evaluate the pipe where the two well connect.

Braves Trail:

- Routine Maintenance

Letitia Lane Pump Station:

- 11/1/24-Inspected pump core found it inoperable. Replaced and installed new Extreme Pump Core.
- 11/22/24-Provided contractor access inside station to diagnose pump.

Media Station:

- Routine Maintenance

Rose Tree Lower

- Routine Maintenance

Rose Tree Park

- Routine Maintenance

Rose Tree Upper

- 11/18/24-Checked station due to no hours on pump #1. Found auxiliary on pump #2 had popped out. Put bac in place. Pump #1 Operating normally.

Toft Woods:

- Routine Maintenance

Valley View:

- Routine Maintenance

Winter Street:

- Routine Maintenance

Recommendations for Repairs**

***Please inform us which repairs are the responsibility of the contractor who did the station build outs and upgrades and which you would like us to attend to/fix.

Please let us know if you have any questions or concerns.

KBX Golden, LLC
439 McFarlan Road
Kennett Square, Pa.