

UPTSA 2024 Pump Station Invoices

Upper Prov./Operations & Maintenance

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
11/1/2024	Upper Providence Township Sewer Authority	2673442	1930867	1	IS-C-WWTP-Lift & Pump Station Operations	\$7,240.33	Monthly O&M	\$7,240.33	6560004395
							Pump Station Total	\$7,240.33	

Upper Prov./Bortondale

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
11/1/2024	Upper Providence/Bortondale	2673442	1930598	3	Project-C-Hours-Foreman-Mechanic	\$99.64	Acquired and applied 2001 locks at pump station	\$298.92	6560005715
11/1/2024	Upper Providence/Bortondale	2673442	1930598	1	Project-Materials	\$140.05	Locks	\$140.05	6560005715
11/4/2024	Upper Providence/Bortondale	2673442	1930598	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Switched operations to the new station and tested.	\$315.63	6560005724
11/11/2024	Upper Providence/Bortondale	2673442	1930598	4	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a power failure alarm. Power restored upon arrival. Observed proper operation before departure.	\$631.28	6560005789
11/14/2024	Upper Providence/Bortondale	2673442	1930598	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Met with contractors to address adjustments to pump station.	\$315.63	6560005849
11/16/2024	Upper Providence/Bortondale	2673442	1930598	4	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a pump failure alarm. VDF had a fault. Cause for alarm unknown. Observed proper operation before departure.	\$631.28	6560005852
11/16/2024	Upper Providence/Bortondale	2673442	1930598	4	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a second pump failure alarm. VDF was at fault again. Put pump #2 in lead.. Observed proper operation before departure.	\$631.28	6560005853
11/18/2024	Upper Providence/Bortondale	2673442	1930598	2	Project-C-Hours-Foreman-Mechanic	\$105.21	Put pumps on alternate during the day to evaluate. Observed four cycles.	\$210.42	6560005864
11/18/2024	Upper Providence/Bortondale	2673442	1930598	1	Repair-C-Hours-Foreman-Mechanic	\$105.21	Responded to a pump #1 failure alarm. Put pump #2 in lead. Observed proper operation before departure.	\$105.21	6560005865
11/19/2024	Upper Providence/Bortondale	2673442	1930598	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Met with contractor to evaluate pump #1 failures. Determined soft start needs to be replaced.	\$315.63	6560005879
11/20/2024	Upper Providence/Bortondale	2673442	1930598	4	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a power failure alarm. Power not restored. Called in power failure to PECO.	\$631.26	6560005891
11/21/2024	Upper Providence/Bortondale	2673442	1930598	2	Project-C-Hours-Foreman-Mechanic	\$105.21	Met with contractor to have old pump station de-energized.	\$210.42	6560005909
11/25/2024	Upper Providence/Bortondale	2673442	1930598	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Removed pumps and components from site during demolition of old station.	\$315.63	6560005927
11/25/2024	Upper Providence/Bortondale	2673442	1930598	3	Project-C-Hours-Mechanic	\$97.54	Removed pumps and components from site during demolition of old station.	\$292.62	6560005928
11/27/2024	Upper Providence/Bortondale	2673442	1930598	2	Project-C-Hours-Foreman-Mechanic	\$105.21	Pumped down wet well in order for contractor to evaluate the pipe where the two well connect.	\$210.42	6560005969
							Pump Station Total	\$5,255.68	

Upper Prov./Letitia Lane

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
11/1/2024	Upper Providence/Letitia Lane	2673442	1930612	1	Project-Materials	\$5,406.00	Inspected pump core found it inoperable. Replaced and installed new Extreme Pump Core.	\$5,406.00	6560005716
11/22/2024	Upper Providence/Letitia Lane	2673442	1930612	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Provided contractor access to station and stayed on site while pump #1 was diagnosed.	\$315.63	6560005920

11/22/2024	Upper Providence/Letitia Lane	2673442	1930612	1	Project-Materials	\$767.99	Contractor preformed meter readings and all readings to pump #1., Pulled pump #1 due to report of issues. Replaced stater. Checked amps on pump #1.	\$767.99	6560005920
							Pump Station Total	\$6,489.62	
Upper Prov/Rosetree Estates Upper									
Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
11/18/2024	Upper Providence/Rose Tree Estates Upper	2673442	1930605	1	Project-C-Hours-Foreman-Mechanic	\$105.21	Checked station due to no hours on pump #1. Found auxiliary on pump #2 had popped out. Put back in place. Pump #1 Operating normally.	\$105.21	6560005866
							Pump Station Total	\$105.21	