

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
11/1/2024	77913

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	11/1/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace DH416693 with new twp pump DH914923  Craig Grattan 60 Diemer Dr Media PA 19063  Date of service 11/4/24 Technician Sebastian Gonzalez  Arrived on site to panel not in alarm. Performed meter readings and all readings were good except amps and switches to pump. Amps were running on 4.2 and switches were giving me high numbers. I lifted up lid to station to find station flooded. I pulled pump #DH416693 and saw that pump was from 06/2011 I went to upper Prov shed to grab customer new core #DH00914923. Once I put new core into station I ran pump to alarm and performed my last meter readings and everything checked out good.  Job completed.				
1	Labor-SGon	Service Call & Inspection Fee Labor rate for Sebastian			170.00	170.00
					130.00	130.00

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.