

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
11/4/2024	77937

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	11/4/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace DH423361 with new twp pump DH911578 Michelle McAllee (Upper Prov) 2111 Kimberwick Rd Media, Pennsylvania 19063-1949 Date of service 11/4/24 Technician Pat Brady Arrived on site and found pump DH423361 In high level alarm and not pumping out I reset the breakers and pump would jump to 26 amps and shut down.I performed meter readings and all readings were incorrect.pulled pump for further evaluation and found that the rotor is locked up.Due to age of pump installed new upper Providence core DH00911578 pump pumped down and shut off at 5.9 amps pump is running correctly				
1	Labor-PB	Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 130.00

OK TO PAY
KEVIN MATSON, PE,
OPERATIONS MANAGER

12/10/2024

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.